

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20211738
Address: 2061 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081
Inspected On: Wednesday, April 06, 2022
Inspected By: Michael Harkins
Expiration Date: 04/29/2022

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Temporary C of O	Wednesday, April 06, 2022

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | -Approval for C of O required from: Field Service Engineer,
Planning, |
| | | - Provide permanent handrail patio ramp |
| | | -Complete vestibule 101; |
| | | - Upload to permit performance test report for kitchen hood
system as required per IMC 507.6. |

** TCO expires 4/29/2022