

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20216411
Address: 710 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary - Material Verification	Eric Sharp	Partial	Wednesday, April 06, 2022

Corrective Action Required:

1	Misc	Had sewer materials delivered. Have wyes for tie in on main and clean outs. Clean out caps, and pipe(all SDR26). Metal Sewer clean out rings and lids. Also had hard back furnco adapters, let Glynn know these would need to be replaced and use Max Adapters. 4/5/22 ES
---	------	---

Comments: