

DEVELOPMENT SERVICES

PLAN REVIEW CONDITIONS

April 06, 2022

lee rhoad

leerhoad@gmail.com

Permit No: PRCOM20221121

Project Title: TERRA SUPPLEMENTS & SUPERFOODS

Project Address: 1237 NE DOUGLAS ST, LEES SUMMIT, MO 64086

Parcel Number: 5291015040000000

Location / Legal MAPLE TREE PLAZA 2ND PLAT---LOT 3 (EX PT IN ROW)

Description:

Type of Work: NEW TENANT FINISH

Occupancy Group: MERCANTILE

Description: TENANT FINISH FOR SALE OF SUPPLEMENTS

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200 Fire Department (816) 969-1300

Fire Plan Review Reviewed By: Jim Eden Approved

Building Plan Review Reviewed By: Joe Frogge Rejected

7. 2018 IMC 403.2 Outdoor air required. The minimum outdoor airflow rate shall be determined in accordance with Section 403.3. (see code for exception) Action required: Revise drawings to show outside air calculations as well as method of delivery.

Action required: Provide outdoor air calculations and method of delivery.

4/5/22 - Method of delivery not found in design.

8. HVAC design completion in question. Duct sizes incomplete. Return air looks inadequate. What is purpose of drywall chase and how is it constructed? Where is condensing unit? How is condensing unit screened from view?

Action required: Modify design to comply.

4/5/22 - condensing unit information not found in design

Licensed Contractors Reviewed By: Joe Frogge Approved



DEVELOPMENT SERVICES

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.