

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215017
Address: 126 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Shawn Hoffman	Passed	Thursday, April 07, 2022

Corrective Action Required:

1	Miscellaneous Correction	(3) PIERS 18 X 22 PIERS SHALL EXTEND BELOW THE FROST LINE MIN DEPTH OF 36" BELOW GRADE PER PLAN COLUMN & PIER SCHEDULE SHEET A2 : BREAK IT OF PROVIDE ENGINEERS LETTER :
---	--------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: