



March 8, 2022

K&E Flatwork

Re: 1617 SW 27th St
Lot 37, Whispering Woods
Lee's Summit Permit #: PRRES 20216043

Apex Engineers, Inc. observed the preparation for the suspended garage slab at the above referenced address.

The garage slab will be suspended. The forms and reinforcing steel were found to be clean, well aligned, properly supported, and in general compliance with the approved prints.

Note:

- The inspection was performed at 11:45 am
- At the time of the inspection the temperature was 37°.
- Erosion control needs repair at front of lot.

Our firm recommends approval of the garage slab for the placement of concrete. This report does not constitute approval by the enforcing jurisdiction

LIMITATIONS

The recommendations and conclusions given in this report are based on the observed conditions at the time of this site visit. The scope of our services was only to observe the installation of the slab formwork and reinforcing steel.

The contractor is responsible for following ACI cold weather protection methods; therefore, Apex Engineers, Inc. cannot be held responsible for the impact and/or damages caused to the structure if ACI cold weather procedures are not followed and maintained.

Please call if Apex Engineers, Inc. can be of further assistance.

Best Regards,

A blue ink signature of Christopher Veith.

Christopher Veith
Senior Engineering Technician

Clayton J. Hess, P.E.
Principal

