

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214650
Address: 415 SW JEFFERSON ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Robb Popp	Failed	Thursday, April 07, 2022

Corrective Action Required:

1	Miscellaneous Correction	NO CITY STAMPED/APPROVED PLANS ON SITE BASEMENT FINISH IS COMPLETE NO UNDERSLAB PLUMBING INSPECTION ON RECORD NO IN WALL INSPECTION ON RECORD NO ABOVE CEILING INSPECTION ON RECORD OPEN J BOXES STORAGE ROOM, MECH ROOM NM CABLES SHALL NOT BE PERMITTED AS FOLLOWS (2) EXPOSED WITHIN A DROPPED OR SUSPENDED CEILING CAVITY IN OTHER THAN ONE-AND TWO FAMILY AND MULITIFAMILY DWELLINGS (2017 NEC 334.12 (A) (2))
---	--------------------------	---

Comments: