## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20213528

Address: 2361 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Shawn Hoffman Failed Thursday, April 07,

Residential 2022

Corrective Action Required:

1 Misc

- Fire block DWV in return air space master bathroom (at stud shoe)
- Provide 3 1/2" steel columns both sides of gaming room per plan
- Fire block penetration in plenum space bedroom 4 basement

**Comments:**