

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213528
Address: 2361 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Shawn Hoffman	Failed	Thursday, April 07, 2022

Corrective Action Required:

1	Miscellaneous Correction	Provide proper clamp for aluminum conductor to steel ufer. Acorn not suitable for this location 4/7/22 no change
---	--------------------------	--

Comments: