

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212682  
Address: 1841 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed	Thursday, April 07, 2022

Corrective Action Required:

1	Misc	-rock screw pattern inspection will need to be performed after given approval of wall bracing design GB at garage, great room, dining room, foyer, bed#2, bed#3, 2nd floor hall, master bed, master closet; min 1/2" rock screwed 7" oc edges and wall, both faces of wall, see page 5 braced walls
---	------	---

**\*\*OK TO INSULATE AND ROCK\*\***

**Comments:**