

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211947  
Address: 4416 SW ALABASTER CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mark Harding	Failed	Thursday, April 07, 2022

Corrective Action Required:

1	Misc	-CS-PF portal bracing design at dining room windows and dining room sliding glass door per plans, nail exterior sheathing per plans/IRC R602.10.6.4, check the nailing, remove trim can't see nail pattern  see manufactures listing on siding. over driven nails need to be caulked and re-nailed. see email.MARK HARDING 04/07/2022 4:21 PM
---	------	---

Comments: