

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212467  
Address: 4821 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Friday, April 08, 2022

Corrective Action Required:

1	Misc	-Studs not continuous from floor to ceiling at front bedroom gable wall **Reinforce wall studs across plates. You can install 24" straps centered to plates and nailed to studs per typical engineer practice or have engineer address
---	------	---

**Comments:**