

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20211138
Address: 1201 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Sediment Control (ESC) Inspection	Ronald Paynter	Failed	Friday, April 08, 2022

Informational:

1	Misc	No erosion issues to report on the job site today. RP 3-23-22
---	------	---

Informational:

2	Misc	Another rain day, still no erosion issues to report. RP 3-24-22
---	------	---

Corrective Action Required:

3	Misc	Curb and field inlets are full of silt and there is excess silt in the roadways. RP 4-4-22
---	------	---

Corrective Action Required:

4	Misc	Curb inlets are still full of silt. RP 4-8-22
---	------	---

Comments: