

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20210775
Address: 1201 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|----------------|----------|------------------------|
| Erosion Sediment Control (ESC) Inspection | Ronald Paynter | Failed | Friday, April 08, 2022 |

Informational:

| | | |
|---|------|---|
| 1 | Misc | No erosion issues to report on the job site today. RP 3-23-22 |
|---|------|---|

Informational:

| | | |
|---|------|---|
| 2 | Misc | Another rain day, still no erosion issues to report. RP 3-24-22 |
|---|------|---|

Corrective Action Required:

| | | |
|---|------|---|
| 3 | Misc | Curb and field inlets are full of silt and there is excess silt in the roadways. RP 4-4-22 |
|---|------|---|

Corrective Action Required:

| | | |
|---|------|---|
| 4 | Misc | Curb inlets are still full of silt. RP 4-8-22 |
|---|------|---|

Comments: