

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213306
Address: 4805 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Adam Nacke	Passed	Friday, April 08, 2022

Informational:	
1 Misc	4-5-22 AN forms are in place and aggregate is present and compacted.
Informational:	
2 Misc	4-8-22 AN driveway looks good and has expansion joints at curb and right. Meets Ada specs

Comments: