CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20212196

Address: 1630 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Erosion Sediment Control (ESC) Adam Nacke Passed Friday, April 08, 2022

Inspection

Corrective Action Required:

1 Miscellaneous 1-20-22 AN. Dirt needs to be cleaned off the street and curb line also Small

Correction section of silt fence needs to be repaired

Corrective Action Required:

2 Misc 2-1-22 AN Welch was out here putting up more silt fence but the streets and

curbs still need to be cleaned up

Informational:

3 Misc 2-9-22 AN Holthouse has someone with a shovel cleaning up the curbs

Informational:

4 Misc 2-10-22 AN. Holthouse has a bobcat with a sweeper cleaning the streets

Corrective Action Required:

5 Miscellaneous 3-22-22 AN 7th & 8th plat, need to get some more silt fence put up and get

Correction the dirt cleaned up off the street and clean front of storm boxes

Corrective Action Required:

6 Miscellaneous 3-30-22 AN emailed Holthouse about silt in roadway. Needs to get cleaned

Correction up and a lot more silt fence

Corrective Action Required:

7 Miscellaneous 3-31-22 AN silt fence down on the perimeter of the south side. Also as I said

Correction before you need to get a lot more silt fence up ASAP! A large amount of silt is

getting into the roads and the storm boxes. Both 7th and 8th plat

Corrective Action Required:

8 Miscellaneous 4-1-22 AN. Had Kara Taylor come out to see the erosion issues and we did a

Correction stop work order

Informational:

9 Misc 4-6-22 AN Josh form Holthouse was cleaning up the streets and had Welch

putting up silt fence.

Comments: