

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20211138  
Address: 1201 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Sediment Control (ESC) Inspection</b>	Ronald Paynter	Partial	Monday, April 11, 2022

Informational:

1	Misc	No erosion issues to report on the job site today. RP 3-23-22
---	------	---

Informational:

2	Misc	Another rain day, still no erosion issues to report. RP 3-24-22
---	------	---

Corrective Action Required:

3	Misc	Curb and field inlets are full of silt and there is excess silt in the roadways. RP 4-4-22
---	------	---

Corrective Action Required:

4	Misc	Curb inlets are still full of silt. RP 4-8-22
---	------	---

Informational:

5	Misc	Curb inlets have been cleaned out. RP 4-11-22
---	------	---

**Comments:**