

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212479
Address: 3112 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Monday, April 11, 2022

Corrective Action Required:

1	Misc	TCO UNTIL 3/22/22
---	------	-------------------

spoke with connor with Summit Homes. Requested a TCO Extension 04/08/22

Spoke with ethan with summit homes.
requesteed a TCO extension, TCO extened until
4/14/22

- resolve outstanding inspection fee
- final sidewalk and driveway inspection required, contact development services to schedule
- lower water meter lid to grade, maintain required 14" - 18" clearance from top of meter to top of lid

Comments: