

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210625
Address: 2110 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Monday, April 11, 2022

Corrective Action Required:

1	Miscellaneous Correction	Provide final grade Provide sod Remove dust covers smoke detector Provide clamp at AC whip Sump shall discharge 36" from foundation Sewer tracer wire shall be in a box at grade level
---	--------------------------	---

Comments: