

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220404
Address: 940 NW PRYOR RD, Unit:F, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Failed	Monday, April 11, 2022

Corrective Action Required:

1	Miscellaneous Correction	Provide boca plates at dwv Provide midpoint support vertical dwv 2" & smaller Complete plumbing for mop sink, floor drain, Toilet
---	-----------------------------	--

Comments: