

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212186
Address: 1121 NE GOSHEN CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Khanh Nguyen	Failed	Tuesday, April 12, 2022

Corrective Action Required:

1	Misc	-Install covers at SE conductor connections to main breaker -Ground electrical service to water line with #4 cu GEC
---	------	------------------------------------------------------------------------------------------------------------------------

Comments: