

*David P. Ainsworth, P.E.*  
*1200 NW Hearn Ave, Blue Springs, MO 64015*  
*Cell Phone: 816-682-2093*  
*Email: dainsworth@chelepis.com*

April 12, 2022

Mr. Mark Yancik  
508 NW Manor Drive  
Blue Springs, MO 64014

Re: Property @  
4816 NE Jamestown Dr  
Lee's Summit, MO.  
Monticello Lot 124  
Deck Pier Inspection

Dear Mr. Yancik:

On April 12, 2022, I inspected the deck pier hole for the above referenced property. The hole was 18" diameter by about 9' deep. Reinforcing steel was on site for the pier.


The plans call for 2 piers but the other post is supported by the retaining wall.

The pier is approved for concrete placement.

Cordially,



David P. Ainsworth, P.E.



4-12-22