

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211543
Address: 1905 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Partial	Tuesday, April 12, 2022

Corrective Action Required:

1	Misc	-Complete electrical to fireplace **plug connection must be accessible at final
		**Gas line to the patio fireplace-OK
		**Siding must be min 2" above the concrete slab, or install material that will not degrade from water damage

Comments: