



**LEE'S SUMMIT**  
MISSOURI



---

**FIRE DEPARTMENT**

**Prevention Division**  
**(816)969-1300**

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20220404	Date:	March 31, 2022
Project Title:	EUROPEAN WAX CENTER	Applicant:	
Location:			
940 NW PRYOR RD, Unit:F, LEES SUMMIT, MO 64081		CAMM CONSTRUCTION INC	
Type of Work:		PO BOX 1417	
Occupancy Group:	B	LEES SUMMIT, MO 64063	
Description:	TENANT FINISH FOR WAX CLINIC	Primary: (816) 607-3602	
Construction Type:	Type VA (1 hour)		
Map Page:			

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Alarm Plan Review**

**Reviewed By: Jim Eden**

**Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule a test.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**