

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212465
Address: 536 SE CARTER RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Tuesday, April 12, 2022

Corrective Action Required:

1	Misc	-Provide tension straps at PFG-STRAPS NEED TO EXTEND FROM TOP PLATE TO JACK STUDS -Provide (2) 1/2" anchor bolts and plate washers at PFG-TIGHTEN NUTS -(3) columns in basement to be 3.5" schedule 40-NOT ADDRESSED -All I joist to be protected at final **OK TO INSULATE
---	------	---

Comments: