

**DEVELOPMENT SERVICES**

**Residential Plan Review**

April 12, 2022

RISING SUN SOLAR  
3525 ROANOKE RD #116  
KANSAS CITY, MO 64111  
(816) 489-4154

Permit No: PRRES20221278  
Plan Name:  
Project Address: 1509 SW GEORGETOWN DR, LEES SUMMIT, MO 64082  
Parcel Number: 69700130200000000  
Location: THE RESERVE AT STONEY CREEK 3RD PLAT LOTS 60-110 & TRS L-N----LOT 67  
Type of Work: ALTERATION SINGLE FAMILY  
Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY  
Description: ROOF MOUNTED SOLAR - 5.8 KW

***Revisions Required***

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide two (2) copies of any revised sheets and/or additional information.***

Development Services Department (816) 969-1200

**Residential Plan Review**

**Reviewed By: Joe Frogge**

**Rejected**

2. Exterior conductors must be rated for wet conditions.

Action required: Update conduit schedule to comply.  
4/7/22 - Not addressed. THHN is not rated for wet conditions.

**Fire Department Solar Review**

**Reviewed By: Jim Eden**

**Approved**

***The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.***

<b>Residential Area:</b>			
<b>Roofing Material</b>		<b>Number of Bathrooms</b>	
<b>Number of Bedrooms</b>		<b>Number of Stories</b>	
<b>Number of Living Units</b>		<b>Total Living Area</b>	

