

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20214077  
Address: 3104 SW ARBORTREE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Tuesday, April 12, 2022

Corrective Action Required:

- |   |                          |   |
|---|--------------------------|---|
| 1 | Miscellaneous Correction | <ul style="list-style-type: none"><li>- Provide front door</li><li>- Block siding breaks above double garage bay</li><li>- Fire block chase at top plate at DWV garage</li><li>- Nail all exterior intersecting corners to code</li><li>- Strap both sides of entry top plate not tied in</li><li>- Address broken trusses A2 in kitchen</li><br/><li>- fire block top plate at soffit basement north west corner</li><li>- Fire block soffit to joist space at basement door and bedroom 3</li><li>- Security blocking basement door</li></ul> |
|---|--------------------------|---|

**Comments:**