CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204944

Address: 214 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Sidewalk Inspection Ronald Paynter Partial Tuesday, April 12, 2022

Informational:

1 Misc Forms were placed and aggregate was present and compacted. RP 4-12-22

Comments: