

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20211958  
Address: 2020 SW HOOK RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Coliform Test 1</b>	Diana Johnson	Passed	Wednesday, April 13, 2022

Informational:

1 Misc

On Monday 4.4.2022 Redford Construction began chlorination of the water pipe lines

On Wednesday 4.6.2022 Redford collected 1st Water Samples 7 samples were collected and taken to Keystone Labs

On Thursday 4.7.2022 Redford collected 2nd Water samples 7 samples were collected and taken to Keystone Labs.

**Comments:**