

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214472
Address: 2946 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, April 13, 2022

Corrective Action Required:

2	Miscellaneous Correction	- Expose PFH portal frame for inspection - Fur out garage at laundry - Strap top plate both sides of the front door - Missing hanger foyer hallway corner - Anchor bolts middle 1/3 of plate basement - Security blocking basement door 3 bays out - Protect electrical panel from DWV above - Complete vent and ductwork in basement bathroom
---	--------------------------	--

Comments: