

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20214472  
Address: 2946 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:            | Inspector:    | Outcome: | Date:                     |
|------------------------|---------------|----------|---------------------------|
| <b>Erosion Control</b> | Shawn Hoffman | Failed   | Wednesday, April 13, 2022 |

Corrective Action Required:

|   |                                       |                                                                                                                                                                                            |
|---|---------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | DCM2 ESC<br>DEFICIENT<br>INSTALLATION | DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS<br>UNTIL ADEQUATE EROSION CONTROL PROVIDED.<br><br>MAINTAIN GRAVEL FILTER<br>REPAIR SILT FENCE<br>REMOVE DEBRIS FROM STREET |
|---|---------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**Comments:**