

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212479
Address: 3112 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Not Ready	Wednesday, April 13, 2022

Corrective Action Required:

1	Misc	4/12/22 - RESCHEDULE INSPECTION WHEN ALL CORRECTIONS COMPLETE
---	------	---

Spoke with ethan with summit homes.
requesteed a TCO extension, TCO extened until
4/14/22

-resolve outstanding inspection fee
-final sidewalk and driveway inspection required, contact development
services to schedule
-lower water meter lid to grade, maintain required 14" - 18" clearance from
top of meter to top of lid

****4/13/22- NO ITEMS FROM THIS LIST HAVE BEEN ADDRESSED, NOT READY
FEE ACCESSED

Comments: