

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215503
Address: 142 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Michael Harkins	Failed	Wednesday, April 13, 2022

Corrective Action Required:		
1	Miscellaneous Correction	PROVIDE GUAGE WITH MIN 10 PSI INSTALL FIREPLACE COVERED DECK (GAS LINE) INSTALL FURNACE (GAS LINE)

Comments: