

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213528
Address: 2361 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Wednesday, April 13, 2022

Corrective Action Required:

1	Misc	- Fire block DWV in return air space master bathroom (at stud shoe) - Provide 3 1/2" steel columns both sides of gaming room per plan - Fire block penetration in plenum space bedroom 4 basement
---	------	---

Corrective Action Required:

2	Misc	inspection denied no address posted erosion control not in compliance
---	------	--

Comments: