

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20221296
Address: 1002 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Michael Harkins	Not Ready	Wednesday, April 13, 2022

Corrective Action Required:

1	Misc	sheetrock needs to be cut out and panel cover to fit tight against panel. recall when completed.
---	------	---

PAY NOT READY FEE

(4/13/22 NOT DONE STILL A 3/8" GAP)

Comments: