

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20221294
Address: 612 SW 3RD ST, Unit:B, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Michael Harkins	Failed	Wednesday, April 13, 2022

Corrective Action Required:	
2 Miscellaneous	PROVIDE PLUGS FOR OPEN KNOCK OUTS IN SERVICE PANEL
Correction	PER 2017 NEC 110.12 (A)

Comments: