



April 13, 2022

Walker Custom Homes, LLC
Attn: Jason Walker

Re: 2812 Hearthstone Place, Lee's Summit, MO (Lot 53)


Vista Structural Engineering, LLC, was asked to address the following city rough-in inspection comments for the house being built at 2812 Hearthstone Place, in Lee's Summit, MO:

- **Wall studs between windows at back of great room not framed as specified on plans.** *The plans call for a minimum of two king studs. If the two outer trimmers are strapped as shown on the following page, these studs will support all the imposed design gravity and lateral (wind) forces. We recommend approval of these studs with the aforementioned strapping.*

Our firm appreciates the opportunity to serve you. If you have any questions or if you need anything further, please feel free to contact us.

Sincerely,
Vista Structural Engineering, LLC


Dennis Heier, P.E.



VISTA STRUCTURAL ENGINEERING, LLC

14718 NW DELIA STREET
PORTLAND, OREGON 97229

PHONE: 971.233.6099
VISTASTRUCTURAL.COM



VISTA STRUCTURAL ENGINEERING, LLC

14718 NW DELIA STREET
PORTLAND, OREGON 97229