



CIVIL ENGINEERING CONSULTANTS

1805 WATERS ROAD

HARRISONVILLE

MISSOURI

64701

816-380-5150

FACSIMILE: 816-884-3250

EMAIL: MAIL@REOENGINEERING.COM

April 4, 2022

Jack Greene
Dreams & Designs Buildings
P.O. Box 7014
Lee's Summit, MO 64064

RE: R.E.O. Project #21-002-55
MD2 Designs Plan #: DD-7167
1717 SW 27th St.
Lot 31, Whispering Woods
Permit #: 20202309

Dear Mr. Greene,

We are providing herewith approval of the glu-lam beam at the outer rim of the deck in lieu of a mid-span column and footing at the above referenced project. The as-built deck rim beam is a 3.5x12.375 20F-E1 spanning approximately 16 feet. The beam is adequate for the applied loads and shall be installed as required by the manufacturer.

No modifications are required for this alternate rim installation. It is considered approved as-is. If there are any questions regarding this statement, please contact our Offices.

Very Truly Yours,

R.E.O. ENGINEERING, P.C.

By: , President
Aaron D. Obermiller, P.E.

