

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212070  
Address: 209 NW JOSHUA DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                    | Inspector:      | Outcome: | Date:                    |
|--|-----------------|----------|--------------------------|
| <b>Piers/Caissons Inspection - Residential</b> | Michael Harkins | Passed   | Thursday, April 14, 2022 |

Corrective Action Required:

|   |                          |  |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | PLANS CALL FOR (2) 24 X 36 COVERED DECK PIERS SYMBOL K ISOLATED FOOTINGS AND COLUMN PADS SCHEDULE THESE ARE 16 X 33 19X35 ON 10/25/22 ENGINEERS LETTER ADDRESSING PIERS LOADED TO PERMIT |
|---|--------------------------|--|

**Comments:**