

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210101  
Address: 329 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Not Ready	Thursday, April 14, 2022

Corrective Action Required:

1	Miscellaneous Correction	Obtain lawn irrigation permit & submit back flow certification Under slab plumbing failed 3/2/21 Pay not ready fees Provide wet rated fixture above master tub ( per 2018 IRC E4003.11) Provide (2) 1/2 through bolts deck beam to post connection ( PER 2018 IRC FIGURE R507.5.1(2) Provide splash blocks
---	--------------------------	--

Comments: