

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216223
Address: 106 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - R	Michael Harkins	Failed	Thursday, April 14, 2022

Corrective Action Required:		
1	Miscellaneous Correction	PROVIDE MIN 2" CLEAN GRAVEL IN METER PIT PER LS SPECS 14" MIN 18" MAX METER TO PIT LID

Comments: