

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20202439
Address: 1901 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Retaining Wall Inspection	Michael Harkins	Passed	Thursday, April 14, 2022

Informational:
1 Misc - EAST PICNIC SHELTER -
- (4) 36 X 36 PIERS W/ (8) # 6 VERT BARS WRAPED WITH # 4 TIES 12 OC W/ 2
TIES IN TOP 5", DRIVEN GROUND ROD ON NE PIER -

Comments: