

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220431

Address: 420 SW LONGVIEW BLVD, Unit:116, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Shawn Hoffman	Partial	Friday, April 15, 2022

Informational:

1	Miscellaneous Correction	-Framed out bathroom in unit A south end of building. Studs rock against ceiling and fire caulked under stairs. - 4/15/22 inspection of fist layer (shaft liner) and fire caulk on ceiling of bathroom building A
---	-----------------------------	--

Comments: