

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213827
Address: 4709 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Friday, April 15, 2022

Corrective Action Required:

1	Misc	-Strap garage PFH wall header -Provide fall protection for bedroom windows -Fb wall plate penetration by dryer duct -At rear master bedroom wall, strap top plates and protect plumbing -Connect duct to fan above master toilet room -Nail siding at roof flashing at left master closet wall -Strap across cut top plates at front bedroom gable wall
---	------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

****OK TO INSULATE**

Comments: