

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212569
Address: 2353 SW HICKORY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Friday, April 15, 2022

Corrective Action Required:

1 Misc

*Okay to insulate do not cover any items still needing inspection. *

- pfh to be completed per plans/design (anchor bolt to be of correct size)
- protect all NM with in 6ft of attic access bed 4 closet
- complete electrical in unfinished area

Comments: