CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20220073Address:3534 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Friday, April 15, 2022
Corrective Action Required:			
1 Misc	-nail all exterior sheathing per plans -exterior bracing CS-PF at great room windows per plans, nail exterior sheathing per plans/engineer letter, remove trim and nail sheathing to header, leave trim off above window for reinspection, IRC R602.10.6.4		
	ok to insulate and rock		

Comments: