

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213631
Address: 425 NW KAYLEA CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Friday, April 15, 2022

Corrective Action Required:

1	Miscellaneous Correction	-Provide CS-PF per plan at sliding glass door -Apply sheathing to interior side of wall at patio door per plan -Provide 3 studs exterior wall corner bed 4 -Furr out dwv at ceiling bed 4 closet,(fireblock around DWV top plate, will need bocca plate as well) ok to insulate
---	--------------------------	---

Comments: