## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20214592

Address: 805 NE ALGONQUIN ST, LEES SUMMIT, MO 64064807 NE ALGONQUIN ST, LEES SUMMIT, MO

64064809 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

**Gas Service Inspection -** Khanh Nguyen Failed Friday, April 15, 2022

Residential

Corrective Action Required:

1 Misc -No access to units 805&807. All pressure gauges held for min ten minutes

**Comments:**