

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20210263

Address: 520 NW HOPE LN, Unit:IR, LEES SUMMIT, MO 640811801 NW OBRIEN RD, LEES SUMMIT, MO  
64081520 NW HOPE LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	Michael Harkins	Failed	Friday, April 15, 2022

Corrective Action Required:

1	SECOND FLOOR	2nd FLOOR PER PLAN AREA A CORRIDOR FIRE CAULK WATER & ELECTRICAL PENETRATIONS PROVIDE ENGINEERS LETTER ADDRESSING NOTCHED LVL NEAR FOYER AT ELEVATOR # 1
---	--------------	--

**Comments:**