CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSITE20221062 Address: 904 NW PRYOR RD, LEES SUMMIT, MO 64081908 NW PRYOR RD, LEES SUMMIT, MO 64081900 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 2	Ronald Paynter	Passed	Monday, April 18, 2022
Informational:			
1 Misc	Met Tyler and pulled second Bac T sample. Delivered sample to Keystone Laboratories for testing. Still waiting to hear the results on the first sample. RP 4-14-22		
Informational:			
2 Misc	Samples passed second Bac T testing. RP 4-18-22		

Comments: