

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212023
Address: 3030 NW THOREAU PL, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Monday, April 18, 2022

Corrective Action Required:

- | | | |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | <ul style="list-style-type: none">- Provide city stamped plans- Fire block cantilever into garage from pantry- Plans call for 3 1/2" columns and 3" installed- Anchor all columns |
|---|--------------------------|--|

Ok to insulate

Comments: